



PLAN VIEW



NOTES:

1. ASSEMBLY SHALL BE A USC APPROVED DEVICE.
2. THE RP SHALL BE INSTALLED ABOVE GRADE.
3. FREEZE PROOF INSULATED BOX AND 1 SOURCE OF HEAT ARE REQUIRED. 2 SOURCES OF HEAT ARE STRONGLY RECOMMENDED.
4. NO STOP AND WASTE VALVES.
5. INSULATED BOX SHALL SWING CLEAR OF ASSEMBLY TO PROVIDE CLEARANCES SHOWN IN PLAN VIEW OR INSULATED BOX SHALL BE SIZED TO PROVIDE CLEARANCES SHOWN IN PLAN VIEW.
6. SPRING LOADED LID REQUIRED ON LARGE BOXES.
7. CALL LOCAL BUILDING AND/OR FIRE DEPARTMENTS FOR DEPTH AND TYPE OF PIPE TO BE USED.
8. INSPECTION BY TMWA BACKFLOW PREVENTION GROUP PERSONNEL REQUIRED BEFORE METER IS SET OR SERVICE IS ACTIVATED.
9. TESTING OF BACKFLOW ASSEMBLY REQUIRED WITHIN 7 DAYS AFTER METER IS SET OR SERVICE ACTIVATION. COPY OF TEST RESULTS TO BE FORWARDED TO TMWA BACKFLOW PREVENTION GROUP PERSONNEL BY A CERTIFIED ASSEMBLY TESTER WITHIN THAT SAME TIMEFRAME.
10. MINIMUM DIMENSIONS FOR THE THRUST BLOCK BEARING AREA FOR PIPE 2" AND SMALLER SHALL BE 8" X 8" AND 12" IN DEPTH. ALL OTHER SIZES TO BE DETERMINED BY ENGINEER.



DATE

7/2001

REV

2/2010

APPENDIX 10A
 BACKFLOW PREVENTION ASSEMBLIES
 FIRE - CLASS 4, 5, & 6 REDUCED PRESSURE
 PRINCIPLE DETECTOR ASSEMBLY
 EXTERNAL - HORIZONTAL

DRAWING NUMBER

10A-10